

## Netball Design Guidance for Indoor Club Courts

Description		Requirements	
		Minimum	Preferred
Principal Playing Area (PPA) <sup>1</sup>	Length	30.50m	
	Width	15.25m	
	Height	≥ 7.50m	
Run Offs (R/O) <sup>2</sup>	Ends	2.00m	3.05m
	Sides	1.5m	3.05m
	Between courts with common side run off <sup>3</sup>	2.00m	4.00m
	Between courts with side dividing boards or net	3.00m	6.10m
Space for team benches and match officials	Optional		
Overall space requirement for a single court excluding any optional spectator seating	Length	34.50m	36.60m
	Width <sup>6</sup>	18.25-20.25m	21.35-23.35m
	Height	≥ 7.50m	
Spectator seating	Optional		
Class of surface	Class 2		Class 1
Line Markings	Width	50mm required	
	Colour	Preferably white Where another sport has priority, red or blue (but not yellow) can be used.	
	Tolerances	All lines to be within ±15mm of their specified positions	
Goalposts	Type	Free standing and height adjustable	Socketed (with flush cover plate when not in use) and height adjustable
	Protection	Height adjustable protective padding along the length of the goal post. Padding to be of uniform thickness not more than 50mm thick.	
	Height	Adjustable ring heights of 3.05m, 2.75m and 2.44m to allow use for Wheelchair Netball and High 5 Netball.	
Lighting	Minimum maintained illuminance <sup>4</sup>	500 lux	
	Uniformity ratio <sup>5</sup>	≥ 0.7	

### Notes

1	Dimensions as specified in the INFs Official Netball Rules, 2015
2	Run off distance between side line and any permanent or temporary fixture, wall etc. Run offs to have the same playing surface as the playing area. They shall be free of any permanent or temporary fixture to a height of 3.5m
3	Common run off where courts are laid side by side with no division nets etc. between them
4	Measured on a 5m grid centred on the centre circle and including a 1m margin around the perimeter of the PPA
5	Uniformity ratio = Emin/Eave
6	Width range is dependent on inclusion of optional team bench and match officials area (T/O).

