

Netball Design Guidance Series

Indoor Premier Courts

Description		Require	ements
		Minimum	Preferred
Principal Playing Area	Length	30.50m	
(PPA) ¹	Width	15.25m	
	Height	≥ 7.50m	
Run Offs (R/O) ²	Ends	2.00m	3.05m
	Sides	1.50m	3.05m
	Between courts	3.00m	4.00m
	with common side		
	run off³		
	Between courts	3.00m	4.00m
	with common end		
	run off		
	Between courts	3.00m	6.10m
	with side dividing		
	boards or net		
	Between courts	4.00m	6.10m
	with end dividing		
	boards or net		
Space for team	Required		
benches and match	2.0m wide by court length		
officials			
Overall space	Length	34.5m	36.60m
requirement for a	Width	21.25m	23.35m
single court excluding	11.1.1.		
any spectator seating	Height	≥ 7.50m	
Spectator seating and refreshments		Recommended.	
		Specific requirements determined by level of	
		competition being catered for.	
		Provision must be clearly defined, outside	
		the field of play.	
Class of surface	_	Class 2	Class 1
Line Markings	Width	50mm required	
	Colour	Preferab	<u> </u>
		Where another sport has priority, red or blue (but not yellow) can be used.	
	Tolerances		nin ±15mm of their
	A11	specified	
	Alternative formats	<u> </u>	tball line markings ⁴ .
Goalposts	Type Socketed or floor fixed (with flush or		·
	D I	plate when not in use).	
	Protection Protective padding along the leng		
			g to be of uniform
		thickness not more	e than 50mm thick.



Netball Design Guidance Series

	Height	3.05m with optional height settings at 2.75m and 2.44m.	
	Post diameter	Between 80mm – 100mm, positioned so that back of the post aligns with the outside edge of the goal line ⁵ .	
Lighting	Minimum maintained illuminance ⁶	750 lux	
	Uniformity ratio ⁷	≥ 0.7	
	Ancillary areas	Safe and appropriately lit routes that link	
		entry points, and facilities such as bus stops,	
		car parks, cycle parks and toilet facilities are	
		required.	
Toilets		Required, as per <u>NetballHer</u> and <u>HSE</u>	
		guidance.	
Changing		Required.	
accommodation		Capacity levels determined by level of	
		competition being catered for.	
Broadcast / live		Access to either a private wifi network or	
streaming		hardwire internet cable with minimum	
		upload speed of 10mbps.	
		Access to fixed tracking cameras or balcony	
		space for portable equipment.	

Notes	
1	Dimensions as specified in World Netball's 'Rules of Netball' 2024 Edition.
2	Run off distance between side/goal line and any permanent or temporary fixture, wall etc. Run offs to have the same playing surface as the playing area. They shall be free of any permanent or temporary fixture to a height of 3.5m
3	Common run off where courts are laid side by side or end or end with no division nets etc. between them
4	For details of 'Fast 5' netball line marking, please refer to <u>World Netball's</u> technical guidance.
5	Goalpost position as specified in World Netball's 'Rules of Netball' 2024 Edition.
6	Measured on a 5m grid centred on the centre circle and including a 1m margin around the perimeter of the PPA
7	Uniformity ratio = Emin/Eave

Version: 3

Date updated: 24 September 2024