

Daily Water Quality Assessment Sheet
LAG, Rio de Janeiro, Brazil


Date: 15th August 2016, 06:30 hrs

1. Water Quality Analysis (last six results)

1a. Enterococci Levels

Date of Sample	LRF1	LRF2	LRF3	LRF5	Enterococci Standard (NMP/100mL)
12/08/2016	<1	<1	<1	<1	200
11/08/2016	<1	<1	1	1	200
10/08/2016	1	1	<1	5	200
09/08/2016	<1	6	4	10	200
08/08/2016	0	4	2	6	200
07/08/2016	2	2	6	17	200

Key:



Note: The WHO 'Proper' Enterococci standard of 200 NMP/100ml will be used due to advice from the WHO.

1b. E.Coli Levels

Date of Sample	LRF1	LRF2	LRF3	LRF5	E.Coli Standard (NMP/100mL)
13/08/2016	130	240	240	130	2000
12/08/2016	46	240	350	46	2000
11/08/2016	2	8	8	8	2000
10/08/2016	23	11	7	22	2000
09/08/2016	2	8	13	240	2000
08/08/2016	23	33	31	33	2000

2. Weather report (today and forecast five days)

Day	Weather
15/8/2016	Sunny
16/8/2016	Cloudy (20% chance of rain)
17/8/2016	Sunny (10% chance of rain)
18/8/2016	Overcast (40% chance of rain)
19/8/2016	Overcast (20% chance of rain)
20/8/2016	Overcast (20% chance of rain)

4. Weather forecast (previous six days)

Day	Weather
14/8/2016	Sunny
13/8/2016	Sunny
08-12-16	Heavy rain in morning, clearing
08-11-16	Sunny with scattered cloud
08-10-16	Overcast, light rain and wind
08-09-16	Sunny and overcast in evening


4. Canal Openings (for past five days)

Day	Open	Comments
14/8/2016	Y	Water flow into Lagoa
13/8/2016	Y	Water flow into Lagoa
08-12-16	Y	Water flow into Lagoa
08-11-16	Y	Water flow into Lagoa
08-10-16	Y	Water flow into Lagoa

5. Visual and Olfactory Inspections (last 12 hours)

Site	Visual Pollution	Odour	Nessler results	Aquatic biodiversity behaviour	Time of visit	Comments
Pipe 2	None	None	No sewage	Normal	06.30 - 07.30hrs	Pipe submerged
Pipe 9	None	None	No sewage	Normal	06.30 - 07.30hrs	Pipe submerged
Pipe 35	None	None	No sewage	Normal	06.30 - 07.30hrs	Pipe submerged
Pipe 53	None	None	No sewage	Normal	06.30 - 07.30hrs	
LRF1	None	None		Normal	06.30 - 07.30hrs	
LRF2	None	None		Normal	06.30 - 07.30hrs	
LRF3	None	None		Normal	06.30 - 07.30hrs	
LRF5	None	None		Normal	06.30 - 07.30hrs	

Key:



6. Summary:

'Excellent water quality' (E.Coli < 2000 or Enterococci < 200). With a 'very low' sanitary inspection result. A rating of 1 given.

7. Decision

No change to competition schedule